

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202946
Address: 2337 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Miscellaneous Correction	-MAINTAIN EROSION CONTROL AND PROTECT SWALE AND FIELD UNTIL SOD IS IN PLACE -FINAL GRADE AND SOD -SPLASH BLOCKS AND SUMP EXTENSION -MAX BREAKER AT AC TO BE 40 AMPS -ALL ROUGH INSPECTION NOT PASSED-ADDRESS ALL ITEMS
---	--------------------------	--

Comments: