

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204576  
Address: 1721 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Misc	-Nail exterior wall sheathing per code -Support valley rafters above great room to beam, not ceiling joists -Provide CSPF framing where required per A/4 on the plan (rear dining, master bedroom walls) -Brace interior walls per plan -Have engineer address support of the 16" lvl point load at foyer wall. It currently bearing on subfloor only
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**\*\*OK TO INSULATE**

**Comments:**