

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202309
Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Misc	-PROVIDE CITY APPROVED, STAMPED PLANS FOR INSPECTION -Fb double stud wall near refrigerator-SEAL GAPS AT LAUNDRY SIDE -Expose deck roof ridge support framing -Move master closet roof support to bearing wall -Studs not continuous full height at front bedroom gable wall-HAVE ENGINEER APPROVE CORRECTION -Fb all basement wall vertically at max ten ft interval, including space above windows -Complete basement bedroom closet ceiling framing and fire block as required-SEAL GAPS -Have engineer address over-notched joist above front basement bedroom -Provide brace walls per A/4 detail -Brace interior walls per plan
---	------	--

**OK TO INSULATE

Comments: