

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210156
Address: 2042 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Failed	Friday, August 06, 2021

Informational:

1	Misc	Forms were placed and aggregate was present and compacted. There is 2 water valves in the driveway approach. I informed them that we have to have access to them after they pour the approach. RP 8-2-21
---	------	--

Corrective Action Required:

2	Misc	Both water valve risers are busted. Need to remove and replace with new risers. RP 8-6-21
---	------	---

Comments: