

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204445
Address: 102 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Miscellaneous Correction	Pay outstanding fees Provide back flow certification for lawn irrigation Provide guard rail at front porch over 30" to grade Seal exterior light fixtures Provide access to GFCI receptacle at jacuzzi tub master Seal exterior penetrations irrigation & low volt near meter can, sump discharge Seal top of ac disconnect & meter can Sump shall discharge 36" from foundation Corner hangers at deck ledger
---	--------------------------	--

Comments: