

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210281
Address: 1509 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Misc	-Fireblock around DWV at chase garage, vertical to horizontal at the furred down -seal all top plate penetrations-see master bed south wall, 2nd floor bath#2, 2nd floor bed#2 -protect flex gas line at fireplace entrance -OK to insulate only at dining room and great windows that required osb installed on interior wall. Reinspection of installed osb required before rock - see engineer letter
---	------	--

Comments: