

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210587
Address: 1505 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Misc	-Fireblock chases great room around DWV gaps -LIB bracing all locations per plans - see garage -seal top plate penetrations- bed#5 1st floor -Seal floor penetrations at 2nd floor low volt at HVAC chase master bed -add receptacle for jacuzzi tub motor electrical
---	------	---

Comments: