

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203516
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Failed	Friday, August 06, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PRE FINAL MEP FINAL REQUESTED : 8/6/21 pre final MEP final Concession stand south end of football field Complete open J boxes Complete light fixtures canopy Complete gutters & roof drains Women's Restroom in former concession stand Provide missing cover plates electrical Check city approved plans on ADA sinks in this room Men's restroom 18" vertical grab bar SOUTH TICKET BOOTH Install Backordered light fixtures or provide cover plates on open J boxes Label service panels Complete roof drains NORTH TICKET BOOTH Install backordered light fixtures or provide cover plates open J boxes
---	-----------------------------	--

Label service panels
Complete roof drains

CONCESSION STAND UNDER BLEACHERS

Complete wiring at service panels
Label service panels
Provide GFCI protection next to 3 compartment sink
Cover plate light switch at elevator
Guard under stairway

2ND FLOOR PRESS BOX

Install fixtures or cover plates in open J boxes

3RD FOOR

No power to check GFCI
Install missing fixtures or provide cover plates open J boxes

Comments: