

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20204839
Address: 3104 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Tom Taylor	Passed	Monday, August 09, 2021

Informational:

1 Misc

On Thursday, 8-05-2021. ESS Excavating completed soil stabilization and compacted subgrade.

On Monday, 8-09-2021. ESS Excavating preformed finish grading for sub-grade proof roll.

Comments: