

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204976
Address: 2910 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|--------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Tuesday, August 10, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Resolve outstanding inspection fees before final c of o -Final grade and sod -splash blocks at downspouts and sump pump -complete stone/siding front of house -finished basement wet bar -install fixture or cover plate at ceiling box basement den -complete deck stairs at landing, 7 3/4" max rise -attic access required -Handrail required at garage stairs |
|---|------|--|

Comments: