

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210837  
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, August 04, 2021

Informational:

1 Misc

GARAGE PFH PORTAL FRAME  
HOLDDOWNS & 3" O.C. NAILING APPROVED  
OK TO COVER

5/8 ANCHOR SHALL BE IN MIDDLE 1/3 THE WIDTH OF PLATE  
CHECK ABOVE ON ROUGH IN

Corrective Action Required:

2 Misc

NO CITY APPROVED PLANS ON SITE

**Comments:**