

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210837
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Tuesday, August 10, 2021

Corrective Action Required:

1	Misc	IDENTIFY UFER GROUND BOTH ENDS, UFER GROUND REQUIRED, SEE LOCATION NOTED AT FOOTING, FOUNDATION WALL FT STOOP/GARAGE - LOCATE UFER & GROUND SERVICE PANEL -
---	------	--

Comments: