

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204436
Address: 1508 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Tuesday, August 10, 2021

Corrective Action Required:
2 Misc ADDRESS EROSION CONTROL ON LOT, REQUIRED UNTIL SOD IS PLACED.
PROTECT SWALE AND STORM INLET AT REAR OF LOT

Comments: