

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211978
Address: 540 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Robb Popp	Failed	Thursday, August 12, 2021

Corrective Action Required:

1	Misc	-10' of copper required from meter to house -Bed copper lines and meter pit in gravel -Complete pex to line to house -Ensure that meter pit is at proper elevation and provide 14" to 18" from top of meter to top of can
---	------	--

Comments: