

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210837  
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, August 12, 2021

Informational:

1 Misc

GARAGE PFH PORTAL FRAME  
HOLDDOWNS & 3" O.C. NAILING APPROVED  
OK TO COVER

Corrective Action Required:

2 Misc

-lvl master closet per plans ( NO LVL)  
2 X 6 JOIST DOUBLED UP PER DAVID AINSWORTH LETTER ( NO LETTER IN DOCUMENTS )  
-submit engineer letter concerning change from lvl ridge beam to steel ridge beam at great room ( NO LETTER IN DOCUMENTS)

UPLOAD ENGINEER LETTERS TO PERMIT SO ALL INSPECTORS HAVE ACCES

OK TO ROCK

**Comments:**