## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20210699Address:3109 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectior	1:	Inspector:	Outcome:	Date:
All Rough Residentia	Inspection - al	Patrick Schonfeldt	Passed	Thursday, August 12, 2021
Informatio	onal:			
1	Misc	CORRECTIONS BELOW WILL MOVE TO OCCUPANCY INSPECT TO CHECK WITH COMPLETE DECK -Deck ledger attachment per code -(2) 1/2" through bolts required at each post/beam connection per code		

Comments: