

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210699  
Address: 3109 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, August 12, 2021

Corrective Action Required:

1	Misc	CORRECTIONS BELOW MOVED FROM ALL ROUGH TO OCCUPANCY, CHECK WITH COMPLETED DECK -Deck ledger attachment per code -(2) 1/2" through bolts required at each post/beam connection per code
---	------	--

**Comments:**