

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213804
Address: 4075 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Failed	Thursday, August 12, 2021

Corrective Action Required:

1	Misc	THE REAR 36" PAD IS UNDERMINED (ADJACENT TO OVERDIG)
**OK TO POUR THE REST OF THE FOOTING, EXCEPT THE ABOVE		

Comments: