CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203927

Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Above Ceiling Inspection Patrick Schonfeldt Partial Thursday, August 12,

2021

Informational:

1 Misc Customer service not ready from red wall to the east sheetrock wall, wires

handing below grid. grid incomplete.

Clinic area- MC incomplete, plumbing and water lines through ceiling over

desk

--

existing shopping cart area- open wiring and electrical boxes open to the

public. cover or demo out accessible electrical ASAP.\
Inspection not ready next not ready will result in a fee.

MARK HARDING 07/02/2021 9:36 AM

Corrective Action Required:

2 Misc ALL ceiling tile was installed over the clinic area, remve and recall. nothing

was approved to install tile.

- customer serivce area:

tile installed from red wall to tall wall behind CS red wall without approval, open boxes, low voltage supported by gas pipe, sprinkler piping, ceiling grid.

All electrical needs to be supported 4.5 ft and low voltage over the constrution areas need to be supported offf the bar joist not from other

equipment.

Informational:

3 Misc

8/12 - CEILING ABOVE STARBUCKS AND FRONT NORTH VESTIBULE OK

Comments: