CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20204442
Address:	2009 NW ASHURST DR, LEES SUMMIT, MO 64081
Inspected On:	Friday, August 13, 2021
Inspected By:	Michael Harkins
Expiration Date:	9/10/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Friday, August 13, 2021

Corrective Action Required:

1	Miscellaneous	Sidewalk inspection still pending
	Correction	Provide final grade, sod & splash blocks
		Lower water meter lid to grade
		Repair broken window dining room
		Provide through bolts deck beam to post connection
		Sump discharge 36" from foundation
		Seal exterior penetrations irrigation at garage