

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213111  
Address: 1801 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Khanh Nguyen	Failed	Friday, August 13, 2021

Corrective Action Required:

1	Misc	-Cannot use 3" waste stack to vent the shower trap. Vent the whole bath group per code. FYI: You can install dry vent for the shower trap, then wet-vent the toilet before connecting to the building drain
---	------	---

Comments: