

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210833
Address: 940 NW PRYOR RD, Unit:H, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Monday, August 16, 2021

Corrective Action Required:

1	Miscellaneous Correction	HARD LID IN LOBBY COMPLETE SPRINKLERS, COMPLETE LIGHT FIXTURES
---	-----------------------------	---

Comments: