

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211947
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------|----------|-------------------------|
| Water Service Inspection - R | Robb Popp | Passed | Monday, August 16, 2021 |

Informational:
1 Misc PARTIAL ON PEX TO HOUSE ENTRANCE

Comments: