CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212613 Address: 2050 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectior	1:	Inspector:	Outcome:	Date:
In-wall Ins	spection	Michael Harkins	Passed	Monday, August 16, 2021
Informatio	onal:			
1	Misc -	- ELECTRIC, PLUMBING, FRAMING, APPROVED		

Comments: