

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210880
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, August 17, 2021

Corrective Action Required:

1	Misc	: PFH PORTAL FRAME ONLY : NAIL TOP PLATE TO HEADER W/ 16 SINKERS PER PLAN CHECK ABOVE ON ROUGH IN OK TO COVER EXTERIOR NO PLANS ON SITE FOR COVRED DECK FRONT PORCH NOT DONE
---	------	---

Comments: