

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210252  
Address: 138 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:      | Outcome:  | Date:                      |
|--------------------------------------|-----------------|-----------|----------------------------|
| <b>Electrical Service Inspection</b> | Michael Harkins | Not Ready | Wednesday, August 18, 2021 |

Corrective Action Required:

|   |                          |                                 |
|---|--------------------------|---------------------------------|
| 1 | Miscellaneous Correction | PROVIDE METER CAN W/ DISCONNECT |
|---|--------------------------|---------------------------------|

**Comments:**