

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212339
Address: 1033 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Wednesday, August 18, 2021

Corrective Action Required:

1	Misc	-INSPECTION DENIED DUE TO EROSION CONTROL DEFICIENCY. -BACKFILL TO PROVIDE FULL VISUAL ACCESS TO PLUMBING
---	------	--

Comments: