

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211217
Address: 2101 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, August 18, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide 4 studs GT bearing point entry coat closet per plan Provide LIB pantry per plan Seal upward penetrations pantry Nail exterior wall sheathing east side garage Tighten anchor bolts garage Strap over over bored top plate bed #2 interior load bearing wall Replace missing stud at tub bath #2 Provide 2 nails in LIBs top & bottom Seal upward penetration master shower pex Seal exterior penetration master shower Tighten anchor bolts basement Anchor bolts basement shall be in middle 1/3 of width of plate
---	--------------------------	--

Comments: