

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Nick Lightner	Failed	Thursday, August 19, 2021

Corrective Action Required:

1	Misc	8/19/21 NL - Silt Fence needs to be cleaned up and re-installed. Silt and rock needs to be removed from the street. Pictures attached!
---	------	--

Comments: