

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20212200
Address: 4724 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Nick Lightner	Failed - Stop Work	Thursday, August 19, 2021

Corrective Action Required

1	Miscellaneous Correction	-Restore silt fence at perimeter and storm inlet -Clean debris from storm inlet
---	--------------------------	--

Corrective Action Required

2	Misc	8/19/21 NL - Restore silt fence at the front of the lot and clean up the silt on the NE corner of the property. Silt fence needs to be installed in the rear of the lot, original silt fence has been taken over by silt runoff. Due to no fence in the rear shutting down future inspections till items have been corrected.
---	------	---

Comments: