

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212561
Address: 940 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|-----------------|----------|---------------------------|
| Above Ceiling Inspection | Michael Harkins | Partial | Thursday, August 19, 2021 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | - STUDIO # 1 SEAL PENETRATION 1 HOUR WALL SOUTH SIDE, COMPLETE VENT TO ROOF. ALL OTHER AREAS OK TO DROP CEILING TILES - |
|---|--------------------------|--|

Comments: