

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204442
Address: 2009 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, August 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	Sidewalk inspection still pending-NOT COMPLETED Provide final grade, sod- 6" fall in 10' required for drainage away from foundation, see Southwest Lower water meter lid to grade-14" to 18" from top of meter to top of can required AS WELL AS LID BEING AT GRADE Place tracer wire in box at grade Repair broken window dining room-NOT DONE
---	--------------------------	---

Comments: