

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204750  
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Friday, August 20, 2021

Corrective Action Required:

1	Misc	SIDEWALK INSPECTION STILL PENDING PROVIDE SOD-ENSURE 6" FALL IN 10' FOR FOUNDATION DRAINAGE SUBMIT BACKFLOW CERTIFICATION -PLACE TRACER WIRE IN BOX AT GRADE Complete deck-(2) 1/2" THROUGH BOLTS AT POST TO BEAM CONNECTIONS  - TCO EXPIRES IN ONE YEAR - WHEN SALES OFFICE CONVERTED BACK TO GARAGE INSPECTION REQUIRED -
---	------	--

Corrective Action Required:

2	Misc	SIDEWALK INSPECTION STILL PENDING
---	------	-----------------------------------

**Comments:**