

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210296
Address: 119 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, August 20, 2021

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. RP 8-12-21
Informational:	
2 Misc	Finished driveway meets LS specs. RP 8-20-21

Comments: