

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210580
Address: 711 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, August 20, 2021

Corrective Action Required:

1	Misc	-Provide fire proof shield or proper 3' clearance to ceiling at MDP per manufacturer -OK to rock trusses
---	------	---

Comments: