

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213776
Address: 3113 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Robb Popp	Failed	Friday, August 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	-PIER PADS WRONG SIZE AND LOCATION -FORMS DON'T ALLOW FOR CONTINUOUS FOOTING -JUMP FOOTINGS ONLY 3" WIDE AT BOTTOM OF FORMS
---	-----------------------------	---

Comments: