

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204069
Address: 3222 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Friday, August 20, 2021

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. The storm manhole for the junction box is located in the sidewalk, but the sanitary manhole is located outside of the sidewalk. RP 8-20-21

Comments: