

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203513  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Passed	Monday, August 23, 2021

Informational:  
1 Misc

: THE FOLOWING AREAS ARE APPROVED :  
PRESS BOX ELEVATOR SHAFT 1" GYPSUM BOARD INNER SHAFT ALL FLOORS  
- 1ST LAYER 5/8 TYPE X OUTSIDE ELEVATOR SHAFT ALL FLOORS -

**Comments:**