

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203513  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Michael Harkins	Passed	Monday, August 23, 2021

Informational:

1	Misc	- UNDERGROUND CONDUIT FOR PRIMARY SOUTH END OF TENNIS COURTS - - 6" & 8" CONDUIT 34' TO SOUTH @ SE END OF TENNIS COURT - - 100' TO SOUTH @ SE END OF TENNIS COURT - - (2) DRIVEN GROUND RODS OUTSIDE ELECTRICAL ROOM DOOR RESTROOMS BLDG -
---	------	--

**Comments:**