

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204751  
Address: 2017 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Deck Final Inspection - Residential</b>	Robb Popp	Failed	Monday, August 23, 2021

Corrective Action Required:

1	Miscellaneous Correction	**8-23-21 -Deck incomplete -Piers not poured, not inspected and full of water -This inspection will be performed at occupancy
---	--------------------------	--

**Comments:**