

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203515

Address: 2608 SW WARD RD, LEES SUMMIT, MO 640822600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Monday, August 23, 2021

Corrective Action Required:

1 Misc

Press box:

- 2 GFCI's on 3rd floor SE,S boxes not working.
- Label Panels.
- Provide 1" clearance to B vent 3rd floor.
- Occupancy load sign 3rd floor.
- install handrail to 3rd floor on north side.

Concession stand:

- Wire 2 locker room heaters.
 - Label all panels.
 - complete sidewalk at southeast corner of building.
 - complete fencing.
- Ticket booth 1&2ok.

Other departments under separate cover.

Comments: