

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263
Address: 520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Ronald Paynter	Failed	Monday, August 23, 2021

Corrective Action Required:

1	Misc	Shamrock and O'Brien needs to be swept and kept clean. Notified Bertie from Haren on 8/19 about the issue and clean the streets. Roadways still haven't been cleaned yet. If not cleaned today, I will issue a STOP WORK ORDER. RP 8-20-21
---	------	--

Corrective Action Required:

2	Misc	Streets were cleaned, but Geiger truck 337 was washing out and runoff was running down to the curb inlet. Storm drain needs to be cleaned out. RP 8-20-21
---	------	---

Comments: