



August 20, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Deck beam to deck post connection for Lot #80 Woodside Ridge – 317 NW Ambersham Dr. Lee's Summit, MO 64082 – Permit # PRRES20210283

This letter addresses the deck beam and deck post connection for Lot #80 Woodside Ridge.

(2) #2 2x10 Deck beam:

- Shall be attached with (2) 1/4" 6" Ledger Lok screws installed on bottom portion of non-continuous post extending from interior of post through deck beam and into trim piece.

(2) #2 2x10 Double Joist at Deck End:

- Shall be attached with (2) 1/4" x 5" Ledger Lok screws into bottom portion of non-continuous post.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a faint, larger blue signature.

Bradley Huxol, PE

