CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203786

Address: 153 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Tuesday, August 24,

Residential 2021

Corrective Action Required:

1 Misc -Provide erosion control at perimeter before any further inspections

-As graded plot plan required

-Final grade and sod

-Provide splash blocks and sump discharge extension
 -Obtain lawn sprinkler permit and backflow certification

-Provide missing exterior lighting- address illumination required at front and

flood light at back

-Install light fixture or cover plate at kitchen island

-Complete plumbing at kitchen sink
-Complete electrical at hot water heater

-GFCI receptacle in basement bath won't reset

-Provide lockouts at range and cooktop breakers

-Seal exterior penetration at inter system bonding terminal

-Secure AC whip at disconnect

-Ensure sewer tracer wire and port are accessible and located at grade level

Comments: