

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213593
Address: 2143 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Michael Harkins	Failed	Tuesday, August 24, 2021

Corrective Action Required:

1	Miscellaneous Correction	- PROVIDE ADDRESS - - COMPLETE INTERIOR DRAIN TILE - - NO FOOTING INSPECTION ON RECORD -
---	-----------------------------	--

Comments: