

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-----------------------------------------------|------------|----------|--------------------------|
| Sanitary Sewer Construction Inspection | Tom Taylor | Passed | Tuesday, August 24, 2021 |

Informational:

1 Misc

On Tuesday 5-11-2021, She Diggs it completed and passed 4 MH Vacuum test along the Sanitary Sewer. There are (3) left to complete.

On Tuesday, 8-24-2021. She Diggs it completed the vacuum testing of the (3) manholes left to be tested. All man holes passed vacuum testing and held 10 lbs of vacuum for 2.5 min.

Comments: