

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211738  
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer Construction Inspection</b>	Ronald Paynter	Partial	Tuesday, August 24, 2021

Informational:  
1 Misc Sanitary connections coming out of the building and grease interceptor are connected with hard back Fernco's. RP 8-23-21

Informational:  
2 Misc They tied into the sanitary main line with a Max Adapter coupler. They are closer to the manhole than the design calls for. RP 8-24-21

**Comments:**