

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202309  
Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, August 24, 2021

Corrective Action Required:

1	Misc	-Fireblock double stud wall near refrigerator-SEAL GAPS AT LAUNDRY SIDE -Studs not continuous full height at front bedroom gable wall-HAVE ENGINEER APPROVE CORRECTION -Have engineer address over-notched joist above front basement bedroom -Provide brace walls per A/4 detail, nail off all metal straps, nailing of exterior sheathing per CS-PF design, see detail page 5 of plans
---	------	---

**\*\*OK TO INSULATE**

**Comments:**