

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204576
Address: 1721 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, August 24, 2021

Corrective Action Required:

1	Misc	-Provide CSPF framing where required per A/4 on the plan (rear dining, master bedroom walls), nail off all metal straps, nail exterior sheathing per CS-PF design -Have engineer address support of the 16" lvl point load at foyer wall. It currently bearing on subfloor only
---	------	--

****OK TO INSULATE**

Comments: