

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Shannon McGuire	Temporary C of O	Tuesday, August 24, 2021

Corrective Action Required:

1

The wall mounted lighting above the rear doors does not meet the minimum UDO standards. Sec. 8.260.B requires all wall-mounted lights to utilize full cut-off fixtures.

Comments: